

August 22, 2014

Re: Schedule 40 PVC Rigid Conduit Manufactured in Woodbridge, Ontario, Canada Facility

To Whom It May Concern:

1/2" through 6" Royal Electrical Solutions Schedule 40 Rigid Conduit pipe shall be manufactured in accordance with CSA, ANSI/UL 651 and NEMA TC-2. It shall be manufactured from virgin PVC compound.

Schedule 40 Rigid Conduit pipe shall be certified to the Canadian Standards Association (CSA) standard C22.2 No 211.2 and Underwriters Laboratories (UL) 651, and conforms to NEMA TC-2. Rigid Conduit shall be installed according to the National Electrical Code (NEC) Article 352.

Sincerely,



Jon Houghton  
President  
Royal Building Products - Shelby