



## TECHNICAL SPECIFICATION

### NAPCO PVC Rigid Conduit 90° Utility Elbows

#### **SCOPE**

This specification covers the requirements for PVC (polyvinyl chloride) 90° Utility Elbows. Nominal sizes of 2" to 6" are manufactured to meet CSA C22.2 No. 211.2.

#### **MATERIALS**

The bends are fabricated from PVC Rigid Conduit pipe, certified to CSA C22.2 No. 211.2.

#### **MARKING**

Markings on the bends are as specified in CSA C22.2 No. 211.2.

#### **TEST REQUIREMENTS**

Quality testing is as per NAPCO's Quality Control program and in accordance with CSA C22.2 No. 211.2.

#### **BEND DIMENSIONS**

Nominal Size/Radius (in)	Part Number	OD (in)	t (in)	Entrance Socket ID, A (in)	Bottom Socket ID, B (in)	Minimum Socket Depth, C (in)
2/24	REE2-24	2.369-2.381	0.154-0.172	2.387-2.399	2.363-2.375	1.125
2/36	REE2-36	2.369-2.381	0.154-0.172	2.387-2.399	2.363-2.375	1.125
3/24	REE3-24	3.492-3.508	0.216-0.242	3.505-3.521	3.484-3.500	1.594
3/36	REE3-36	3.492-3.508	0.216-0.242	3.505-3.521	3.484-3.500	1.594
4/36	REE4-36	4.491-4.509	0.237-0.265	4.506-4.524	4.482-4.500	1.750
4/48	REE4-48	4.491-4.509	0.237-0.265	4.506-4.524	4.482-4.500	1.750
5/36	REE5-36	5.553-5.573	0.258-0.289	5.583-5.603	5.543-5.563	1.937
6/36	REE6-36	6.614-6.636	0.280-0.314	6.647-6.669	6.603-6.625	2.125

