



## TECHNICAL SPECIFICATION

### NAPCO PVC Rigid Conduit 90° Bends

#### SCOPE

This specification covers the requirements for PVC (polyvinyl chloride) Rigid Conduit 90° Bends. Trade sizes of ½" to 6" are certified to CSA C22.2 No. 211.2 and UL 651.

#### MATERIALS

The bends are fabricated from PVC Rigid Conduit pipe, certified to CSA C22.2 No. 211.2 and UL 651.

#### MARKING

Markings on the bends are as specified in CSA C22.2 No. 211.2.

#### TEST REQUIREMENTS

Quality testing is as per NAPCO's Quality Control program and in accordance with CSA C22.2 No. 211.2 and UL 651.

#### BEND DIMENSIONS

Nominal Size (in)	Part Number	L (in)	R (in)	d, Avg. (in)
½	REE1090	1.500	4.000	0.840
¾	REE1590	1.500	4.500	1.050
1	REE2090	1.875	5.750	1.315
1 ¼	REE2590	2.000	7.250	1.660
1 ½	REE3090	2.000	8.250	1.900
2	REE3590	2.000	9.500	2.375
2 ½	REE4090	3.000	10.500	2.875
3	REE4590	3.125	13.000	3.500
3 ½	REE5090	3.250	15.000	4.000
4	REE5590	3.375	16.000	4.500
5	REE6090	3.625	24.000	5.565
6	REE6590	3.750	30.000	6.625

