



TECHNICAL SPECIFICATION

NAPCO Gas Venting System GVS-90 (CPVC) Concentric Vent Termination Kits

SCOPE

This specification covers the requirements for NAPCO GVS-90 (CPVC) 3" and 4" Concentric Vent Termination Kits. These kits are certified by Intertek Testing Services to ULC S636, Type IIB, for use as a vent termination with NAPCO GVS-90 pipe and fittings in installations with a flue gas temperature up to and including 90°C.

MATERIAL

GVS-90 Concentric Vent Termination Kits contain: Two lengths of Schedule 40 CPVC pipe (trade sizes as shown below), One Cap and One Wye. Each kit also contains installation instructions for this product.

DIMENSIONS

Trade Size	Part Number	A (in)	B	C	D (Avg) (in)	L (in)
3" x 20"	52CVKGVSF9003	21	4" Sch 40 CPVC Pipe	2 ½" Sch 40 CPVC Pipe	4.5	29
3" x 32"	52CVKGVSF9003-32	31				49
3" x 44"	52CVKGVSF9003-44	43				61
4" x 36"	52CVKGVSF9004	36	6" Sch 40 CPVC Pipe	4" Sch 40 CPVC Pipe	6.6	56

