



TECHNICAL SPECIFICATION

NAPCO PVC Hydro Quebec Duct Fittings Bell Ends

SCOPE

This specification covers the requirements for PVC (polyvinyl chloride) Hydro Quebec Duct Bell Ends. The non-flared end of these fittings are manufactured to meet the socket dimensional requirements in CSA C22.2 No. 211.1.

MATERIALS

These fittings are fabricated from PVC duct pipe (red in colour), that meets Hydro Quebec B.31.21.1-01 and CSA C22.2 No. 211.1.

TEST REQUIREMENTS

Quality testing is as per NAPCO's Quality Control program.

FITTING DIMENSIONS

Nominal Size (in)	Part Number	ID Entrance	ID Bottom	Length
4 ½"	QBE045	4.820" +/- 0.010"	4.766" +/- 0.010"	5.0"

