



## TECHNICAL SPECIFICATION

### PVC Duct 90 Degree, 42" Radius Sweep Bend

#### SCOPE

This specification covers the requirements for 5", 90 Degree, 42" Radius Sweep Bends, fabricated from PVC (polyvinyl chloride) Duct with a bell end. The duct pipe and bends are certified to the Canadian Standards Association (CSA) standard C22.2 No.211.1.

#### MATERIALS

The pipe is manufactured from high quality PVC compound.

#### PIPE

The pipe used to manufacture this product conforms to CSA C22.2 No. 211.1, Type DB2/ES2 for direct burial or encasement in concrete or masonry.

#### TEST REQUIREMENTS

Quality testing is as per NAPCO's Quality Control program and in accordance with CSA C22.2 No.211.1.

#### BEND DIMENSIONS

Part Number	Nominal Size in (mm)	Outside Diameter (d) in	Wall Thickness (s) in	(L) in
90B5x42	5	5.289 – 5.309	0.150 – 0.160	5.00

