



## TECHNICAL SPECIFICATION

### Electrical Nonmetallic Tubing (ENT) Fittings Threaded Terminal Adapter

#### SCOPE

This specification covers the requirements for Electrical Nonmetallic Tubing Threaded Terminal Adapters in trade sizes ½" to 2", for use with NAPCO ENT. These fittings are certified to the Canadian Standards Association (CSA) standard C22.2 227.1/Underwriters Laboratories (UL) Standard 1653, including concrete tightness requirements.

#### MARKING

ENT Threaded Terminal Adapter markings are as specified in CSA C22.2 No. 227.1/UL 1653.

#### TEST REQUIREMENTS

Quality testing is as per NAPCO's Quality Assurance program and in accordance with CSA C22.2 No. 227.1/UL1653.

#### THREADED TERMINAL ADAPTER DIMENSIONS

Trade Size	A (in)	B (in)	C (in)	D (in)
½"	1.620	½" – 14 NPT	0.600	1.235
¾"	1.548	¾" – 14 NPT	0.797	1.529
1"	1.763	1" – 11-1/2 NPT	1.010	1.793
1 ¼"	2.011	1 ¼" – 11-1/2 NPT	1.375	2.239
1 ½"	2.031	1 ½" – 11-1/2 NPT	1.605	2.463
2"	2.178	2" – 11-1/2 NPT	2.063	2.963

